

WESTLOCK Criterion Specification

Criterion Part Number: 3665-FBN1
Westlock Specification Number: 502 / RQ Rev. 1
Wiring Diagram Drawing Number: TBC
Company/End User: FRAMO
Project:
Country: Bergen, Norway

	Description	Material / Detail	Quantity Per Unit
ENCLOSURE	Housing	Grilamid	1
	Cover	Grilamid – Flat Cover	1
	Rating	Weatherproof	
	Mounting Holes	M8 & M6	4 + 4
	Finish	Natural	
	Conduit Entry	M25	1
Fixings / Internals	Shaft	Namur	1
	Screws	Stainless Steel	4
	Gasket/O-Ring	Buna Rubber	3
	Circlips	Stainless Steel	2
	Terminal Strip	8 Point	1
Input / Output Details	Switches	V3 Gold Plated Mech. SPDT	2
	Solenoid	Falcon II / Anodised Aluminium	1
	Solenoid action	3 Port 2 Way	
	Solenoid Cv	1.1CV	
	Solenoid Connections	¼" BSP	
	Solenoid Coil Voltage	24VDC	1
	Manual Override	Manual Latching	
	Network Card	Not Requested	
Visual Indicator	Beacon Colour	n/a	1
	Indication	None	
	Language	n/a	
	Height	n/a	
Accessories: 1 x Plastic Transit Plug, LOCTITE 243 ON SWITCH SCREWS			
Method of Protection: Intrinsically Safe Area Classification: ATEX II 2G 3D T85°C EE x ia IIC T6 Certificate: DEMKO 02 ATEX 133287X / Korea Register of Shipping			